


(C1) — DEM  
NTS



(E1)  $\frac{NEW}{NTS}$

- NOTES:**
1. EXISTING FEEDER AND CONDUIT TO BE REUSED. TEST CABLES AS REQUIRED TO DETERMINE FUNCTIONALITY. IF CABLES FAIL TESTING REPLACE IN KIND.
  2. EQUIPMENT SHOWN LIGHT AND DASHED SHALL BE DEMOLISHED. DISCONNECT EXISTING BRANCH LOADS CONNECTED TO PANELS PP1, PP2, & PP3 AND TERMINATE FOR FUTURE RECONNECTION.
  3. RECONNECT EXISTING LOADS/FEEDERS TO CIRCUIT BREAKERS IN NEW REPLACEMENT PANEL DPA AS REQUIRED.
  4. RECONNECT EXISTING FEEDER TO NEW REPLACEMENT PANEL DPA AND NEW REPLACEMENT PANELS PP1, PP2, & PP3 AS REQUIRED. RECONNECT EXISTING BRANCH LOADS TO PANELS.

[illegible]